




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

23-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	3.54	10.87	36.45	33.99	14.07	0.81	0.27	50.86	43.45	5.69	4.65	96.19	14.19

Average Frequency	49.90	Frequency Variation Index :	0.206	Standard Deviation :	0.100
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.229	13:04:50	Max	50.106	13:15:00
Min	49.52	0:08:00	Min	49.708	5:45:00

