




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

SRIPERUMBUDUR:Frequency

National Grid Frequency Profile for

01-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	7.29	13.33	32.47	28.26	17.99	0.64	0.03	53.11	41.01	5.88	5.32	92.68	16.45

Average Frequency		49.88	Frequency Variation Index :		0.289	Standard Deviation :		0.123
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.159	17:03:40	Max	50.082	17:15:00
Min	49.36	19:10:00	Min	49.521	19:15:00

