




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

07-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.60	3.53	10.13	36.53	41.02	6.76	1.43	14.27	61.49	24.24	16.08	97.97	30.44

Average Frequency		49.99	Frequency Variation Index :		0.086	Standard Deviation :		0.092
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.29	13:03:50	Max	50.171	10:15:00
Min	49.66	14:45:10	Min	49.772	14:45:00

