




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for

08-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.16	9.80	22.96	36.10	25.84	2.92	0.22	34.94	52.78	12.28	9.33	97.62	19.97

Average Frequency	49.93	Frequency Variation Index :	0.158	Standard Deviation :	0.106
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.212	13:02:10	Max	50.119	13:15:00
Min	49.54	19:10:30	Min	49.729	18:45:00

