




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

04-Dec-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	1.23	15.83	29.21	38.60	13.97	1.16	17.06	52.22	30.72	15.66	98.84	24.76

Average Frequency	50.00	Frequency Variation Index :	0.093	Standard Deviation :	0.096
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.281	23:58:40	Max	50.197	0:00:00
Min	49.76	6:42:30	Min	49.828	17:00:00

