




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

05-Dec-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.05	2.31	15.63	29.07	37.89	12.78	2.27	17.99	47.92	34.10	19.18	97.69	19.29

Average Frequency		50.00	Frequency Variation Index :		0.103	Standard Deviation :		0.101
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.37	13:04:40	Max	50.233	13:15:00
Min	49.69	9:14:00	Min	49.850	15:30:00