




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

06-Dec-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.74	9.42	28.77	42.11	16.85	2.11	10.16	49.20	40.64	21.71	97.89	22.80

Average Frequency	50.02	Frequency Variation Index :	0.088	Standard Deviation :	0.091
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.31	12:03:10	Max	50.186	21:45:00
Min	49.72	18:13:30	Min	49.853	12:30:00

