




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

09-Dec-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.15	3.81	17.91	28.77	34.56	12.03	1.78	22.86	51.74	25.41	11.63	97.07	24.63

Average Frequency	49.98	Frequency Variation Index :	0.123	Standard Deviation :	0.110
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.29	21:58:00	Max	50.199	22:00:00
Min	49.61	6:37:50	Min	49.701	6:45:00