




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

10-Dec-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.51	7.05	18.22	31.54	32.82	8.48	1.38	25.78	49.86	24.36	14.56	98.11	22.59

Average Frequency	49.97	Frequency Variation Index :	0.131	Standard Deviation :	0.110
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.32	23:55:50	Max	50.231	0:00:00
Min	49.67	16:49:10	Min	49.744	17:00:00