




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

17-Dec-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.71	4.99	24.46	37.95	25.20	6.15	0.56	30.15	53.07	16.78	10.14	98.74	19.91

Average Frequency		49.95	Frequency Variation Index :		0.116	Standard Deviation :		0.097
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.266	21:57:50	Max	50.177	22:00:00
Min	49.61	7:38:10	Min	49.728	7:45:00

