




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

20-Dec-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.81	7.97	22.13	31.68	29.87	7.45	0.08	30.91	47.26	21.83	14.40	99.11	18.91

Average Frequency	49.96	Frequency Variation Index :	0.133	Standard Deviation :	0.106
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.211	23:59:20	Max	50.143	0:00:00
Min	49.66	9:17:40	Min	49.740	8:30:00

