




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

21-Dec-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.31	6.68	16.54	35.35	30.80	8.38	1.94	23.53	52.74	23.73	13.47	97.74	22.50

Average Frequency	49.97	Frequency Variation Index :	0.126	Standard Deviation :	0.109
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.41	23:59:50	Max	50.286	0:00:00
Min	49.67	8:21:30	Min	49.765	8:30:00