




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for

25-Dec-14

NTPC-VINDHYACHAL:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.13	8.98	22.21	37.38	21.88	6.50	0.91	33.32	51.23	15.45	8.06	96.96	20.79

Average Frequency	49.94	Frequency Variation Index :	0.161	Standard Deviation :	0.112
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.28	6:03:30	Max	50.170	23:45:00
Min	49.59	7:25:50	Min	49.690	7:30:00