




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

03-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.32	8.06	15.57	30.59	35.72	6.98	1.76	24.97	52.25	22.78	14.11	96.92	23.02

Average Frequency		49.97	Frequency Variation Index :		0.144	Standard Deviation :		0.116
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.293	6:04:30	Max	50.227	6:15:00
Min	49.46	19:52:20	Min	49.631	20:00:00

