




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

BALLIA:Frequency

National Grid Frequency Profile for

06-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.64	10.65	28.59	30.51	23.81	4.59	0.20	40.91	45.87	13.22	8.68	98.16	19.79

Average Frequency		49.93	Frequency Variation Index :		0.175	Standard Deviation :		0.110
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.25	18:02:30	Max	50.133	18:15:00
Min	49.49	0:07:10	Min	49.632	0:15:00

