




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

BALLIA:Frequency

National Grid Frequency Profile for

07-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	8.14	21.43	31.73	25.69	12.47	0.51	0.03	61.33	33.62	5.05	4.64	91.83	10.98

<b>Average Frequency</b>		<b>49.86</b>	<b>Frequency Variation Index :</b>		<b>0.322</b>	<b>Standard Deviation :</b>		<b>0.115</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
<b>MAX</b>	<b>50.126</b>	<b>8:01:50</b>	<b>Max</b>	<b>50.071</b>	<b>8:00:00</b>
<b>Min</b>	<b>49.52</b>	<b>14:38:40</b>	<b>Min</b>	<b>49.618</b>	<b>14:45:00</b>

