




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for

09-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	5.52	14.60	31.09	32.44	14.86	1.46	0.03	51.24	42.71	6.05	4.59	94.45	15.73

Average Frequency		49.89	Frequency Variation Index :		0.237	Standard Deviation :		0.108
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.174	18:02:50	Max	50.077	18:15:00
Min	49.58	21:25:00	Min	49.672	21:30:00

