




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for

12-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	8.07	15.26	28.28	32.37	14.26	1.72	0.04	51.63	44.05	4.31	2.60	91.90	16.46

Average Frequency	49.88	Frequency Variation Index :	0.287	Standard Deviation :	0.119
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.2	17:00:40	Max	50.094	13:15:00
Min	49.48	22:17:20	Min	49.536	22:30:00

