




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for

19-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	1.36	10.35	39.58	40.64	7.59	0.47	11.72	65.25	23.02	15.27	99.53	30.93

Average Frequency		49.99	Frequency Variation Index :		0.065	Standard Deviation :		0.080
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.224	5:04:30	Max	50.154	13:15:00
Min	49.71	19:15:10	Min	49.860	19:30:00

