




POWER SYSTEM OPERATION CORPORATION LIMITED
 NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

22-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.31	13.68	32.59	29.56	20.24	1.59	0.03	48.61	41.53	9.86	8.30	97.66	14.53

Average Frequency		49.91	Frequency Variation Index :		0.203	Standard Deviation :		0.106
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.16	8:02:10	Max	50.117	8:15:00
Min	49.49	19:11:50	Min	49.693	19:15:00

