




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

THRISSUR:Frequency

National Grid Frequency Profile for

26-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	3.21	14.82	34.30	28.43	16.11	2.65	0.49	52.35	38.88	8.77	5.88	96.30	15.02

Average Frequency		49.89	Frequency Variation Index :		0.247	Standard Deviation :		0.116
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.238	18:01:20	Max	50.129	16:15:00
Min	49.46	19:38:40	Min	49.533	19:45:00

