




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

SRIPERUMBUDUR:Frequency

National Grid Frequency Profile for

31-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.31	9.15	22.58	37.41	26.71	2.49	0.35	33.06	55.82	11.12	8.48	98.34	24.78

Average Frequency	49.94	Frequency Variation Index :	0.138	Standard Deviation :	0.099
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.238	13:03:10	Max	50.144	13:15:00
Min	49.63	19:25:30	Min	49.703	19:30:00

