


MERUJIT-Frequency

POWER SYSTEM OPERATION CORPORATION LIMITED
 NATIONAL LOAD DISPATCH CENTRE NEW DELHI
 National Grid Frequency Profile for 21/06/2024



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.03	2.24	23.48	48.95	19.25	6.04	2.28	49.55	48.17	23.59	93.96	26.53

Average Frequency : 50.05 Frequency Variation Index : 0.107 Standard Deviation : 0.088

Instantaneous Frequency		15 minute average Frequency	
MAX	50.486	Max	50.319
Min	49.791	Min	49.908
	16:04:00		16:15:00
	0:09:20		0:15:00

[]