




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NEHU:Frequency

National Grid Frequency Profile for

25-Jun-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	3.44	10.32	24.57	33.21	22.63	4.71	1.13	38.34	46.83	14.83	9.38	95.43	18.07

Average Frequency		49.93	Frequency Variation Index :		0.195	Standard Deviation :		0.120
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.275	18:06:10	Max	50.203	18:15:00
Min	49.46	22:06:30	Min	49.572	22:15:00

