




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

26-Jun-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	9.85	22.63	30.87	24.63	11.22	0.78	0.03	63.38	31.10	5.52	4.76	90.12	9.91

Average Frequency	49.85	Frequency Variation Index :	0.371	Standard Deviation :	0.125
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.17	18:01:50	Max	50.072	8:15:00
Min	49.39	22:07:30	Min	49.548	14:00:00

