




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

BALLIA:Frequency

National Grid Frequency Profile for

29-Jun-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.32	4.33	11.75	33.32	33.09	14.00	3.18	16.41	54.27	29.32	12.55	96.50	24.98

Average Frequency		50.00	Frequency Variation Index :	0.123	Standard Deviation :	0.111
--------------------------	--	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.372	17:08:10	Max	50.315	17:15:00
Min	49.65	0:20:30	Min	49.731	0:30:00

