




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for

2-May-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.59	6.91	25.01	47.81	13.83	5.85	7.50	51.49	41.01	21.39	94.15	26.86

Average Frequency		50.04	Frequency Variation Index :		0.117	Standard Deviation :		0.101
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.49	18:03:40	Max	50.431	18:15:00
Min	49.75	14:16:20	Min	49.833	14:30:00