




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for

3-May-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	1.38	6.71	22.60	39.00	24.19	6.12	8.09	39.46	52.44	22.83	93.88	18.09

Average Frequency	50.05	Frequency Variation Index :	0.126	Standard Deviation :	0.102
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.37	18:03:30	Max	50.211	7:15:00
Min	49.73	14:33:10	Min	49.784	14:30:00