




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for

4-May-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.08	1.50	9.50	33.41	32.16	14.39	8.95	11.09	50.68	38.23	14.97	90.97	23.80

Average Frequency		50.03	Frequency Variation Index :	0.161	Standard Deviation :	0.123
--------------------------	--	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.463	18:20:00	Max	50.377	18:30:00
Min	49.69	0:07:30	Min	49.775	0:15:00