




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for

5-May-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.34	8.06	30.16	37.27	22.72	1.45	8.40	46.88	44.72	20.59	98.55	20.09

<b>Average Frequency</b>		<b>50.03</b>	<b>Frequency Variation Index :</b>		<b>0.091</b>	<b>Standard Deviation :</b>		<b>0.091</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.29	18:20:50	Max	50.209	18:30:00
Min	49.76	21:06:10	Min	49.838	21:15:00