




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

8-May-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	1.56	16.17	28.37	33.88	10.49	9.54	17.74	49.05	33.21	13.29	90.46	22.12

Average Frequency		50.02	Frequency Variation Index :		0.172	Standard Deviation :		0.130
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.5	18:09:00	Max	50.422	18:15:00
Min	49.73	12:32:40	Min	49.793	9:30:00