




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for

9-May-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.14	1.87	8.83	31.16	40.39	16.98	0.63	10.84	53.68	35.47	18.66	99.23	26.01

Average Frequency		50.01	Frequency Variation Index :		0.083	Standard Deviation :		0.090
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.24	5:03:00	Max	50.181	5:15:00
Min	49.67	19:25:20	Min	49.775	19:30:00