




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

10/5/2014



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	2.24	13.80	44.56	33.92	5.02	0.45	16.05	66.72	17.22	11.81	99.55	30.75

Average Frequency		49.98	Frequency Variation Index :		0.071	Standard Deviation :		0.081
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.25	18:03:40	Max	50.139	18:15:00
Min	49.74	23:08:00	Min	49.775	14:30:00