




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for

05-11-2014

HISSAR:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.21	1.92	9.72	32.19	44.86	9.13	1.97	11.85	61.57	26.57	15.57	97.82	31.81

Average Frequency	50.00	Frequency Variation Index :	0.084	Standard Deviation :	0.091
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.352	18:05:40	Max	50.280	18:15:00
Min	49.65	21:10:10	Min	49.801	21:15:00