




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for 13-05-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	1.98	19.07	48.22	28.36	1.83	0.54	21.06	69.85	9.09	6.78	99.46	30.61

Average Frequency		49.96	Frequency Variation Index :		0.074	Standard Deviation :		0.076
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.28	18:06:50	Max	50.178	18:15:00
Min	49.72	10:15:30	Min	49.811	10:30:00