




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

HISSAR:Frequency

National Grid Frequency Profile for 15-05-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.22	10.10	26.22	37.36	22.51	2.29	0.30	37.56	53.94	8.51	5.98	98.49	23.01

<b>Average Frequency</b>		<b>49.93</b>	<b>Frequency Variation Index :</b>		<b>0.150</b>	<b>Standard Deviation :</b>		<b>0.098</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
<b>MAX</b>	<b>50.253</b>	<b>18:03:20</b>	<b>Max</b>	<b>50.127</b>	<b>7:15:00</b>
<b>Min</b>	<b>49.63</b>	<b>19:41:00</b>	<b>Min</b>	<b>49.709</b>	<b>19:30:00</b>