




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

HISSAR:Frequency

National Grid Frequency Profile for 16-05-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	5.01	15.34	32.74	32.11	12.15	2.01	0.64	53.11	40.81	6.08	3.45	94.35	14.92

<b>Average Frequency</b>		<b>49.89</b>	<b>Frequency Variation Index :</b>		<b>0.245</b>	<b>Standard Deviation :</b>		<b>0.112</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
<b>MAX</b>	<b>50.276</b>	<b>23:34:20</b>	<b>Max</b>	<b>50.191</b>	<b>18:15:00</b>
<b>Min</b>	<b>49.51</b>	<b>14:44:30</b>	<b>Min</b>	<b>49.626</b>	<b>10:30:00</b>