




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for 18-05-14

HISSAR:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	5.95	19.18	32.24	23.94	14.69	3.84	0.17	57.40	32.42	10.19	6.25	93.88	11.25

<b>Average Frequency</b>		<b>49.88</b>	<b>Frequency Variation Index :</b>		<b>0.278</b>	<b>Standard Deviation :</b>		<b>0.119</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
<b>MAX</b>	<b>50.221</b>	<b>17:01:20</b>	<b>Max</b>	<b>50.135</b>	<b>17:15:00</b>
<b>Min</b>	<b>49.57</b>	<b>0:16:50</b>	<b>Min</b>	<b>49.668</b>	<b>0:15:00</b>