




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for 21-05-14

HISSAR:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.52	7.67	19.86	44.95	23.41	3.24	0.34	28.07	60.79	11.15	7.60	99.14	23.36

<b>Average Frequency</b>		<b>49.94</b>	<b>Frequency Variation Index :</b>		<b>0.116</b>	<b>Standard Deviation :</b>		<b>0.092</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.235	18:32:20	Max	50.134	18:00:00
Min	49.65	22:09:30	Min	49.768	3:30:00