




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for 23-05-14

HISSAR:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.17	7.25	18.67	39.63	24.75	7.34	1.20	27.11	54.46	18.44	9.97	97.64	22.28

Average Frequency	49.96	Frequency Variation Index :	0.133	Standard Deviation :	0.107
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.305	18:03:10	Max	50.251	18:15:00
Min	49.65	22:17:10	Min	49.725	10:45:00