




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

RIHAND:Frequency

National Grid Frequency Profile for

03-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.53	2.21	11.35	27.70	46.00	11.83	0.38	14.10	54.48	31.42	20.01	99.09	27.70

Average Frequency	50.00	Frequency Variation Index :	0.084	Standard Deviation :	0.092
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.231	13:03:30	Max	50.148	13:15:00
Min	49.66	6:49:00	Min	49.727	6:45:00

