




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

09-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	1.01	12.85	31.00	36.68	15.37	3.10	13.85	51.03	35.12	16.74	96.90	22.63

Average Frequency	50.01	Frequency Variation Index :	0.100	Standard Deviation :	0.099
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.32	21:57:10	Max	50.294	22:00:00
Min	49.73	9:12:10	Min	49.813	3:00:00