




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

10-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.94	7.05	18.80	36.63	28.65	6.41	0.52	27.79	52.52	19.69	12.79	97.53	20.87

Average Frequency	49.95	Frequency Variation Index :	0.138	Standard Deviation :	0.108
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.28	0:00:00	Max	50.143	19:15:00
Min	49.62	5:30:40	Min	49.697	7:00:00