




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

15-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.71	5.20	21.05	52.99	13.52	6.54	5.90	47.29	46.81	26.83	93.46	24.63

Average Frequency		50.04	Frequency Variation Index :		0.104	Standard Deviation :		0.092
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.35	21:46:50	Max	50.293	22:00:00
Min	49.71	17:41:50	Min	49.822	17:45:00