




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

BONGAIGAON:Frequency

National Grid Frequency Profile for

19-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.54	2.73	14.06	36.60	36.32	8.46	1.28	17.34	59.14	23.52	14.27	98.17	27.48

Average Frequency				49.99	Frequency Variation Index :			0.090	Standard Deviation :			0.094
--------------------------	--	--	--	-------	------------------------------------	--	--	-------	-----------------------------	--	--	-------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.27	21:58:50	Max	50.204	22:00:00
Min	49.64	6:21:40	Min	49.731	6:30:00