




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

28-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.65	7.97	17.55	33.84	33.74	5.91	0.34	26.17	52.96	20.87	14.64	99.02	24.24

Average Frequency		49.96	Frequency Variation Index :		0.122	Standard Deviation :		0.104
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.3	0:00:20	Max	50.105	2:00:00
Min	49.59	12:11:40	Min	49.765	11:45:00