




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

06-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.22	12.43	29.35	40.14	14.42	1.23	0.21	44.00	50.00	6.00	4.58	97.57	14.77

Average Frequency	49.91	Frequency Variation Index :	0.179	Standard Deviation :	0.096
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.254	18:01:50	Max	50.083	18:15:00
Min	49.64	19:16:40	Min	49.708	13:30:00

