




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for

16-Oct-14

RIHAND:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	4.48	12.48	28.34	30.00	22.88	1.82	0.00	45.30	47.13	7.57	6.05	95.52	19.84

Average Frequency	49.91	Frequency Variation Index :	0.211	Standard Deviation :	0.111
-------------------	-------	-----------------------------	-------	----------------------	-------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.187	18:02:10	Max	50.057	20:00:00
Min	49.55	18:29:10	Min	49.668	6:00:00