




POWER SYSTEM OPERATION CORPORATION LIMITED
 NATIONAL LOAD DESPATCH CENTRE NEW DELHI

RIHAND:Frequency

National Grid Frequency Profile for

18-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.63	2.82	15.31	36.31	39.34	5.59	0.00	18.76	62.62	18.62	13.62	99.38	32.01

Average Frequency	49.98	Frequency Variation Index :	0.081	Standard Deviation :	0.087
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.198	17:02:00	Max	50.109	0:00:00
Min	49.62	18:27:30	Min	49.758	18:30:00

