




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

RIHAND:Frequency

National Grid Frequency Profile for

19-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	3.60	17.37	34.12	35.00	8.80	1.11	20.97	55.21	23.82	14.50	98.89	27.23

Average Frequency		49.98	Frequency Variation Index :		0.097	Standard Deviation :		0.097
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.367	23:59:40	Max	50.249	0:00:00
Min	49.72	11:20:10	Min	49.783	12:30:00

